

# **TOWNSHIP OF HARDYSTON**

Municipal Building  
149 Wheatsworth Road, Suite A  
Hardyston, NJ 07419

## **SIMPLIFIED REGULATIONS FOR SMOKE DETECTOR, CARBON MONOXIDE ALARM & FIRE EXTINGUISHERS**

1. **One smoke detector on each level within 20 feet of all bedrooms or in each bedroom – must be mounted on the ceiling.**
2. **Carbon Monoxide Detector on each level with bedrooms within 20 feet of said bedrooms – All systems shall be installed in accordance with the manufacturer's published installation instructions and applicable codes and standards.**
3. **Fire Extinguisher –**
  - **Must be mounted within 10 feet of the kitchen**
  - **Must be a 5lb or 6lb size but no more than 10lbs**
  - **Must be ABC multi-purpose type**
  - **Must have a rating of at least 2:A 10:BC minimum**
  - **Must be mounted accordingly – top no more than 5 feet from floor**

***NOTE: All equipment can be purchased at local hardware stores.***

### **NOTE:**

***For further explanation see Detailed Smoke Detector/Carbon Monoxide/Fire Extinguisher regulations or contact Hardyston Township Fire Prevention Bureau at (973) 823-7020 Ext. 9402.***

**Revised May 2009**